Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-10-17-01**

Date: 22/10/2018

Customer : Assistant Executive Engineer,Yelahanka Satellite Town Sub Division, BBMP, Bangalore.

Address : Yelahanka Satellite Town Sub Division, BBMP, Bangalore.

Project Name : Providing RCC drain covering slab to main and cross roads of Giridhamanagara in Ward no.03

Agency : Sri. Doddajala Ashwathaiah Ravindra, No.119, OM Nilaya, Doddajala, Bangalore.

Customer's Reference : EE(YNK.D)E-PMT-20/W.O/20/2018-19

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 17-10-18

Sample ID No : 2018-10-17-01 /01

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 22/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	15/10/2018	22/10/2018	150.05 X 149.87 X 151.30	22488	8.198	407.8	18.1	18.5
2	Drain Concrete	M20	15/10/2018	22/10/2018	149.20 X 149.67 X 151.07	22332	8.317	415.8	18.6	
3	Drain Concrete	M20	15/10/2018	22/10/2018	151.93 X 150.18 X 149.94	22818	8.255	427.4	18.7	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ.
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-೫೬

CIVIL PRO BANGALORE Sig..... Date.....

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****